

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7167-1373:110 Page 1 of 1

CATEGORY: Control Unit (Household)

LISTEE: First Alert Professional, 172 Michael Drive, Syosset NY 11791
Contact: David Kalmus (516) 921-6704

DESIGN: Models FA1340C and FA1220CV* combination household fire and burglary alarm control units. Refer to listee's data sheet for additional detailed product description and operational considerations. Minimum system:

FA1340C, FA1220CV* Control Unit
4100EOLR End-of-line Resistor for Smoke Detector Loop

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 72, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. The system must have the secondary power supply capable of operating the system for at least 24 hours (battery standby) in the normal condition.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as household fire alarm control unit for use with separately listed compatible initiating and indicating devices. This control unit can generate the temporal code pattern fire alarm signal as required per NFPA 72, 1999 Edition. Refer to manufacturer's Installation Manual for details.

NOTE:

1. For household system, **Fire Alarm Verification Feature** (delay of fire alarm) shall not be used in California.
2. Burglary and other non-fire functions were not examined.

XLF: 7167-0078:158

*Rev. 06-06-01



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**